

Netaji Mahavidyalaya Water Testing Laboratory			Address-Netaji Mahavidyalaya, Arambagh, P.O-Arambagh, Dist.-Hooghly, Pin No-712601. Public Health Engineering Dte., Government of West Bengal	
TEST REPORT				
Issued to: -			Report No: NMWTL/Private/2026/204	
GP	VILLAGE	Location		Reporting Date 24-09-2026
PI RSU RAH-I	PI RSU RAH	HEAVEN'S VIEW SCHOOL		Ref. Letter : AS PER INSTRUCTION OF ASST. ENGINEER, PHED, ARAMBAGH, HOOGHLY
Sample Particulars:				
Sample Description : 500 ml ,				
Date of Receive of Sample :			23-09-2026	Type of Sample Drinking Water-Big Dia Tubewell
Date of Starting of Analysis:			23-09-2026	Date of comple 24-09-2026
Sample Collected by:			CHEMIST & BACTERIOLOGIST, NETAJI MAHAVIDYALAYA WATER TESTING LABORATORY	

TEST CERTIFICATE						
1. Physical & Chemical Test Finding						
SL. NO	Test Parameters	Unit	IS : 10500:2012		Result	Remarks
			Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternative Source (Max)		
1	pH	-	6.5-8.5	No Relaxation	7.25	Passed
2	Total Dissolved Solid	mg/l	500	2000	330	Passed
3	Turbidity	NTU	1	5	4.26	Passed
4	Chloride(as Cl)	mg/l	250	1000	-	-
5	Total Hardness(as CaCO ₃)	mg/l	200	600	202.42	Passed
6	Fluoride(As F)	mg/l	1	1.5	-	-
7	Iron (mg/l) as Fe	mg/l	1	No Relaxation	0.78	Passed
8	Arsenic (as As)	mg/l	0.01	No Relaxation	<0.00	Passed
9	Manganese (as Mn)	mg/l	0.1	0.3	0.102	Passed
<ul style="list-style-type: none"> The test results related only to the item(s) tested. Drinking Water -Specification-IS:10500:2012 						
2. Bacteriological Test Finding						

SL. NO	Organisms	IS:10500:2012 (Limit)	RESULTS
2. BACTERIOLOGICAL EXAMINATION :			
1	Total Coli form (TC) CFU/100 ml.	shall not be detectable in any 100 ml Sample	Not Detected in 100 ml
2	Fecal Coli form (FC) CFU/100 ml.	shall not be detectable in any 100 ml Sample	Not Detected in 100 ml

For Netaji Mahavidyalaya
Water Testing Laboratory

Mr. Rami Karan Mishra
Authorized Signatory

Chemist / Bacteriologist
Water Testing Laboratory
Netaji Mahavidyalaya

P. Rong Mallick
Principal
Heaven's View School
Pursurah, Hooghly
W.B. 712401

Manager
Heaven's View School
Pursurah, Hooghly W.B. 712401

Assistant Engineer
Arambagh Sub-Division
P.H.E. Dte.
(Govt. of West Bengal)